



Based on Estonian Regulation No. 49 of the Minister of Economic Affairs and Communications of 26.07.2013 " Requirements and procedure for attestation of the conformity for building materials and construction products" § 3, it has been stated that the construction product

Penetration sealing system PENOSIL Premium Firestop Acrylic/ Olive Acrifoc

placed on the market by

Penosil Eesti OÜ

Suur-Paala 10, 13619 Tallinn, ESTONIA

and produced in the factory

Krimelte OÜ

Suur-Paala 10, 13619 Tallinn, ESTONIA

is submitted by the manufacturer to a factory production control and to the further testing of samples taken at the factory in accordance with a prescribed test plan and that Inspecta Estonia OÜ has performed type testing, the initial inspection of the factory and of the factory production control and performs the continuous surveillance, assessment and approval of the factory production control.

This certificate attests that all provisions concerning the performances described in Inspecta Estonia OÜ instruction

QMW-826-16

were applied and that the product fulfils all the prescribed requirements.

This certificate is first issued on 12.02.2015 and remains valid until 11.02.2020 as long as the conditions laid down in the instruction in reference or the manufacturing conditions in the factory or the FPC itself are not modified significantly. The validity of the certificate can be checked on the Internet at www.inspecta.com/et. Classification and field of direct application is presented in the Annex 1.

Tallinn 25.06.2015

Tõnu Roosaar Manager

Inspecta Estonia OÜ
Teaduspargi 8, 12618 Tallinn, Estonia
Tel +372 659 9470 Fax +372 659 9479
estonia@inspecta.com

Group headquarters: Inspecta Group Oy, Helsinki, Finland

Annex 1 of certificate No ET-0146-15-03, 25.06.2015

Inspecta

Product: Penetration sealing system PENOSIL Premium FireStop Acrylic/Olive Acrifoc

Details of the product description are presented in test report No 13_02508-2-1-a (Tecnalia) and classification report No 13_02508-2-15-1-a (Tecnalia).

Product specification

Type of sealing system:	putty(Olive Acrifoc) + foam (PU-476) + putty(Olive Acrifoc)
Thickness of sealing system:	30mm
Total length of sealing system (Thickness of wall):	200mm
Length of components of sealing system:	
PENOSIL Premium FireStop Acrylic/(Olive Acrifoc) PENOSIL Premium FireRated Gunfoam B1/(PU- 476) PENOSIL Premium FireStop Acrylic/Olive Acrifoc	30mm 140mm 30mm
Service material:	PVC-U (EN 1329-1)
Service diameter :	32mm
Service wall thickness:	3mm
Service end configuration	Uncapped/Uncapped

Penetration sealing system PENOSIL Premium FireStop Acrylic/ Olive Acrifoc is classified according to EN 13501-2:2007+A1:2009 as follows:

EI 240-U/U

Field of application

This classification is valid for the following end use applications:

- 1. Permitted to use in a vertical wall.
- 2. Autoclaved aerated concrete, concrete, block work and masonry separating elements with ≥200mm width and ≥550kg/m³ density is permitted.
- 3. Services from PVC-U according EN 1329-1, PVC-U according EN -1452-1, PVC-U according EN 1453-1, PVC-U according EN 1566-1 are permitted.
- 4. Length of the sealing system ≤ 200mm and thickness ≤30mm is permitted.
- 5. Separation between penetration seals ≥250mm in the both direction (horizontal and vertical) is permitted.
- 6. Service orientation must be perpendicular to the penetration sealing system (and to the supporting construction).

Inspecta Estonia OÜ Teaduspargi 8, 12618 Tallinn Tel +372 659 9470 Faks +372 659 9479 estonia@inspecta.com DOCTA ESTONIA

Annex 1 of certificate No ET-0146-15-03, 25.06.2015

Inspecta

Marking

Product must be marked. Marking consists of:

- Fire resistance class;
- · Number of Certificate;
- · Name of Certification Body;
- · Name of manufacturer;
- · Year of manufacturing;
- Product identification number.



Inspecta Estonia OÜ Teaduspargi 8, 12618 Tallinn Tel +372 659 9470 Faks +372 659 9479 estonia@inspecta.com